## Level 1 Validation Certificate



This document verifies that the Level 1 Validation process was completed. The session details and audit review outcomes are included here.

This certificate is required for submission — alongside the Level 1 validated water audit software file — to the California Department of Water Resources.

Call Date: 9/26/2019

Supplier Name: The City of La Palma  Supplier Participants: Jake Chavira  Key Audit Metrics  Data Validity Score: 59	Validator:  Validator:  Validator:  Validator Qualifications:  Validator Qualifications:  Water Systems Optimization  Water Audit Validator Certification Statement by Validator  Certification Statement by Validator  This water loss audit report has been Level 1 validated per the requirements of California Code of Regulations Title 23. Division
upplier Participants: Jake havira ey Audit Metrics	Validator Qualifications: Certification Statement
Data Validity Score: 59	This water loss audit report has been Level 1 validated per the requirements of California Code of Regulations Title 23, Division 2,
ILI: 1.15	Chapter 7 and the California Water Code Section 10608.34
Real Loss: 15.66 gal / conn / day	All recommendations on volume derivation and Data Validity Grades were incorporated into the water audit. ⊠
Apparent Loss: 6.71 gal / conn / day	
Non-Revenue Water as Percent of Cost of Operating System: 2.9%	

## Level 1 Validation – Water Supplier Confirmation

This document confirms participation in and endorsement of the Level 1 Validation as completed

Resources. This acknowledgement is required for submission — alongside your Level 1 validated water audit software file — to the California Department of Water

Water Audit Period: Water Supplier Public Water System ID Water Supplier Name: 2018 3010100 City of La palma

Water Audit & Water Loss Improvement Steps

Un billed/La Palma Consumption Steps taken in the audit period timeframe to increase data source accuracy, reduce real losses, and/or reduce apparent losses, as informed by the water audit.

Certification Statement by Water Supplier Executive:

and Loss Control Programs, Manual M36, Fourth Edition and in the Free Water Audit Software version 5. 10608.34 and has been prepared in accordance with the method adopted by the American Water Works Association, as contained in their manual, Water Audits This water loss audit report meets the requirements of California Code of Regulations Title 23, Division 2, Chapter 7 and the California Water Code Section

Executive Name (print): Jake C

Jake Chavira

Executive Position:

Water/Maintenance Supervisor

Signature

200g

9/30/19